

Hallmark® Certificate of Conformance and License (CCL)




VELUX America Inc.
PO Box 5001
Greenwood, SC 29648-5001

Mfr ID: 426
For more Information visit www.amscert.com
Website:
TEL: 864-941-4828

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
426-H-695.00	VCM/VCE/VCS + 4646 and smaller + [2005 or 2099 93]	101/I.S.2/A440-11	SKG -PG30; Size tested 1305 x 1305 mm (51.375 x 51.375in); Positive Design Pressure (DP) = 11,052 Pa (231 psf)	1305mm	1305mm	B3621.02-109-44r1	6/7/2012	3/20/2020
426-H-695.01	VCM/VCE/VCS + 4646 and smaller + [2005 or 2099 93]	101/I.S.2/A440-08	Class CW-PG25; Size tested 1305 x 1305mm - Type SKG; Positive Design Pressure (DP) = 7920 Pa (165 psf)	1305mm	1305mm	B3621.01-109-44	6/7/2012	3/20/2020
426-H-695.02	VCM/VCE/VCS + 4646 and smaller + [2005 or 2099 93]	CSA A440 S1-09	DP: +7920/-1197 Pa (+165/-25 psf); Water Penetration Resistance Test Pressure = 720 Pa (15 psf); Canadian Air Infiltration/Exfiltration = A3 Level	1305mm	1305mm	B3621.01-109-44	1/1/2014	3/20/2020

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com