

Hallmark® Certificate of Conformance and License (CCL)



VELUX America Inc.
PO Box 5001
Greenwood, SC 29648-5001

Mfr ID: 426
For more Information visit www.amscert.com
Website:
TEL: 864-941-4828

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
426-H-670.17	[VS or VSE or VSS] + M08 or smaller + [2004 or 2008 or 2099 94]	101/I.S.2/A440-11	SKG-PG105; Size tested 775x1390mm (~30.5x54.75in); Positive Design Pressure (DP) = 19,152Pa (440psf)	775mm	1390mm	NCTL-110-15756-1	7/15/2013	6/10/2021
426-H-670.18	[VS or VSE or VSS] + M08 or smaller + [2004 or 2008 or 2099 94]	101/I.S.2/A440-08	Class CW-PG80; Size tested 775x1390mm (30.5x54.75in) - Type SKG; Positive Design Pressure (DP) = 12,950Pa (270psf)	775mm	1390mm	NCTL-110-15756-1	7/15/2013	6/10/2021
426-H-670.19	[VS or VSE or VSS] + M08 or smaller + [2004 or 2008 or 2099 94]	CSA A440 S1-09	DP: +12.012/-3830 Pa (+270/-80 psf); Water Penetration Resistance Test Pressure = 720Pa (15.04psf); Canadian Air Infiltration/ Exfiltration Level = A3	775mm	1390mm	NCTL-110-15756-1	1/1/2014	6/10/2021

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com