



Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

VELUX America LLC
PO Box 5001
Greenwood, SC 29648-5001

Mfr ID: 426
For more information visit www.amscert.com
Website: <http://www.veluxusa.com/>
TEL: (864) 941-4828

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
426-H-709.14	Dynamic Polycarbonate Domes, 6' by 6', 0.118" Smooth over 0.118" Smooth	101/I.S.2/A440-11	SKP-PG30; Size Tested 1978mm x 1978mm (78" x 78"); Negative Design Pressure (DP) = -2880 Pa (-60 psf)	1978mm	1978mm	G6344.01-109-44	1/17/2017	12/21/2026
426-H-709.15	Dynamic Polycarbonate Domes, 6' by 6', 0.118" Smooth over 0.118" Smooth	101/I.S.2/A440-08	Class CW-PG30; Size Tested 1978mm x 1978mm (78" x 78") - SKP; Negative Design Pressure (DP) = -2160 Pa (-45 psf)	1978mm	1978mm	G6344.01-109-44	1/18/2017	12/21/2026
426-H-709.16	Dynamic Polycarbonate Domes, 6' by 6', 0.118" Smooth over 0.118" Smooth	CSA A440 S1-09	DP = +1440 Pa / -2160 Pa Water Test Press 720 Pa (15.04psf) Can. Air Infil/Exfil. Level=Fixed	1978mm	1978mm	G6344.01-109-44	1/17/2017	12/21/2026

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Rhonda Schotz Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com