

Hallmark® Certificate of Conformance and License (CCL)




VELUX America Inc.
PO Box 5001
Greenwood, SC 29648-5001

Mfr ID: 426
For more Information visit www.amscert.com
Website:
TEL: 864-941-4828

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
426-H-701.13	FCM 4646 (or smaller) + 0010	101/I.S.2/A440-11	SKG-PG135 - Size tested 1308 x 1308 mm (51.5 x 51.5in); Positive Design Pressure (DP) = 46,444 Pa (970 psf)	1308mm	1308mm	NCTL-110-15748-1	4/30/2013	4/23/2021
426-H-701.14	FCM 4646 (or smaller) + 0010	101/I.S.2/A440-08	Class CW-PG100 - Size tested 1308 x 1308 mm (51.5 x 51.5in)-Type SKG; DP = 25,616 Pa (535 psf)	1308mm	1308mm	NCTL-110-15748-1	4/30/2013	4/23/2021
426-H-701.15	FCM 4646 (or smaller) + 0010	CSA A440 S1-09	DP: +25,616/-4788 Pa (+535/-100 psf); Water Penetration Resistance Test Pressure = 720 Pa (15 psf); Canadian Air Infiltration/ Exfiltration Level = Fixed Level	1308mm	1308mm	NCTL-110-15748-1	1/1/2014	4/23/2021

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com