

Hallmark® Certificate of Conformance and License (CCL)




VELUX America Inc.
PO Box 5001
Greenwood, SC 29648-5001

Mfr ID: 426
For more Information visit www.amscert.com
Website:
TEL: 864-941-4828

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
426-H-701.16	FCM 4646 (or smaller) + 0030	101/I.S.2/A440-11	SKG-PG60; Size Tested 1302 mm x 1302 mm; Positive Design Pressure (DP) = 3600 Pa (75 psf)	1302 mm	1302 mm	E4641.01-109-44-r0	2/24/2015	2/9/2025
426-H-701.17	FCM 4646 (or smaller) + 0030	101/I.S.2/A440-08	Class CW-PG45 - Size Tested 1302 mm x 1302 mm - Type-SKG DP = +3600 Pa (+75 psf)	1302 mm	1302 mm	E4641.01-109-44-r0	2/26/2015	2/9/2025
426-H-701.18	FCM 4646 (or smaller) + 0030	CSA A440 S1-09	DP: +3600/-2160 Pa (+75/-45 psf); Water Test Pressure : 720 Pa (15 psf); Canadian Air Infiltration/Exfiltration: Fixed	1302 mm	1302 mm	E4641.01-109-44-r0	2/26/2015	2/9/2025

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Rhonda Schotz, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com