

Hallmark® Certificate of Conformance and License (CCL)




VELUX America Inc.
PO Box 5001
Greenwood, SC 29648-5001

Mfr ID: 426
For more Information visit www.amscert.com
Website:
TEL: 864-941-4828

| <i>Product No.</i> | <i>Product Name</i> | <i>Standard</i> | <i>Rating</i> | <i>Wide</i> | <i>High</i> | <i>Test Report #</i> | <i>CertDate</i> | <i>ExpDate</i> |
|--------------------|---------------------------------------|------------------------------------|--|-------------|-------------|----------------------|-----------------|----------------|
| 426-H-695.06 | VCM/VCE/VCS 4646 (and smaller) + 2006 | 101/I.S.2/A440-11 | SKG -PG60; Size tested 1305 x 1305 mm (51.375 x 51.375in); Positive Design Pressure (DP) = 11,052 Pa (230 psf) | 1305mm | 1305mm | B3622.02-109-44r1 | 7/17/2012 | 3/20/2020 |
| 426-H-695.07 | VCM/VCE/VCS 4646 (and smaller) + 2006 | 101/I.S.2/A440-08 | Class CW-PG45; Size tested 1305 x 1305 mm (51.375 x 51.375in)-Type SKG; Positive Design Pressure (DP) = 7920 Pa (165 psf) | 1305mm | 1305mm | B3622.01-109-44 | 7/17/2012 | 3/20/2020 |
| 426-H-695.08 | VCM/VCE/VCS 4646 (and smaller) + 2006 | ASTM E-1996-05 / ASTM E-1886-05 | Wind Zone 3, Large Missile C, Cycle Pressure +/-50 | 1305mm | 1305mm | B3623.01-109-44 | 7/18/2012 | 3/14/2020 |
| 426-H-695.09 | VCM/VCE/VCS 4646 (and smaller) + 2006 | CSA A440 S1-09 | DP: +7920/-2155 Pa (+165/-45 psf); Water Penetration Resistance Test Pressure = 720 Pa (15.04psf); Canadian Air Infiltration/Exfiltration Level = A3 | 1305mm | 1305mm | B3622.01-109-44 | 1/1/2014 | 3/14/2020 |

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com