

Hallmark® Certificate of Conformance and License (CCL)

VELUX AMERICA INC.

Mfr#: 426

PO BOX 5001

GREENWOOD, SC 29648-5001

TEL: (864) 941-4828



Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
426-H-687.00	TGF 021 1000 and smaller	101/I.S.2/A440-08	Class CW-PG65; Size Tested 521mm (21in)-TDD; Design Pressure = 11970pa (250psf); Canadian Air Infiltration/Exfiltration Level = Fixed; Water Penetration Resistance Test Pressure = 580pa (12.11psf)	650mm diameter		97732.01-109-44	04/19/2010	02/15/2014
426-H-687.01	TGF 021 1000 and smaller	101/I.S.2/A440-05	SP-65; Design Pressure = 11970pa (250psf); Canadian Air Infiltration/Exfiltration Level = Fixed; Water Penetration Resistance Test Pressure = 580pa (12.11psf)	650mm diameter		97732.02-109-44	04/19/2010	02/15/2014
426-H-687.02	TGF 021 1000 and smaller	101/I.S.2/NAFS-02	SP-150 90	650mm diameter		97732.03-109-44	04/19/2010	02/15/2014
426-H-687.03	TGF 021 1000 and TGR 014 1000 and smaller	ASTM E-1996-05 / ASTM E-1886-05	Wind Zone 3, Missile Level C, Cycle Pressure +/-50	650mm diameter		97732.04-109-44	04/19/2010	02/09/2014
426-H-687.04	TGR 014 1000 and smaller	101/I.S.2/A440-08	Class CW-PG80; Size Tested 362mm (14in)-TDD; Design Pressure = 12448pa (250psf); Canadian Air Infiltration/Exfiltration Level = Fixed; Water Penetration Resistance Test Pressure = 580pa (12.11psf)	445mm diameter		97739.01-109-44	04/19/2010	02/09/2014
426-H-687.05	TGR 014 1000 and smaller	101/I.S.2/A440-05	SP-80; Design Pressure = 12448pa (250psf); Canadian Air Infiltration/Exfiltration Level = Fixed; Water Penetration Resistance Test Pressure = 580pa (12.11psf)	445mm diameter		97739.02-109-44	04/19/2010	02/09/2014
426-H-687.06	TGR 014 1000 and smaller	101/I.S.2/NAFS-02	SP-150 110	445mm diameter		97739.03-109-44	04/19/2010	02/09/2014

WDMA HEREBY CERTIFIES that the aforesaid Company (“Licensee”), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the products set forth above were tested and found to comply with the standards.

By: John McFee John McFee, Certification Mgr, WDMA Hallmark

Program Sponsor:
Window and Door Manufacturers Assoc
401 N. Michigan Ave.
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Services, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com