

# Hallmark® Certificate of Conformance and License (CCL)



VELUX America Inc.  
PO Box 5001  
Greenwood, SC 29648-5001

*Mfr ID:* 426  
*For more Information visit* [www.amscert.com](http://www.amscert.com)  
*Website:*  
*TEL:* 864-941-4828

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
426-H-672.11	FS + M08 (or smaller) + [2005 or 2099 93]	101/I.S.2/A440-11	SKG-PG105; Size tested 781x1397mm (~30.75x55in); Positive Design Pressure (DP) = 19,152Pa (400psf)	781mm	1397mm	NCTL-110-15985-1	8/1/2013	8/19/2021
426-H-672.12	FS + M08 (or smaller) + [2005 or 2099 93]	101/I.S.2/A440-08	Class CW-PG80; Size tested 781x1397mm (30.75x55in)- Type SKG; Positive Design Pressure (DP) = 11,990Pa (250psf)	781mm	1397mm	NCTL-110-15985-1	8/1/2013	8/19/2021
426-H-672.13	FS + M08 (or smaller) + [2005 or 2099 93]	CSA A440 S1-09	DP: +11,990/-3591 (+250/-35 psf); Water Penetration Resistance Test Pressure = 720Pa (15.04psf); Canadian Air Infiltration/ Exfiltration Level = Fixed	781mm	1397mm	NCTL-110-15985-1	1/1/2014	8/19/2021

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

*By:*  *John McFee, VP of Certification Programs, WDMA Hallmark*

*By:*  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 100 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)